## SOFTLINE FIRE-RATED ACCESS PANELS

# WALL 60 MINUTES CEILING 30 MINUTES



The SOFTLINE 60-minute fire-rated inspection hatches are specially designed to be integrated into the walls of service ducts with a minimum thickness of 25 mm. They meet the requirements of fire resistance classification EI 60. They protect against fire spreading from a location within the duct.

The metal surface of the powder-coated frame conceals the aperture in the wall, giving a seamless appearance. The square key lock prevents opening by unauthorised persons.

#### **ADVANTAGES**

- A RAL 9016 coating provides anti-corrosion protection and gives a seamless appearance.
- Simple mounting using swivel wall fixings.
- Closes with a lockable square key.
- Acceptable substrates: plaster board or concrete.
- Installation in wall partition or ceiling.

#### **APPLICATION SPECIFICATIONS**

- For mounting in a wall partition or ceiling.
- Customised dimensions on request, up to the maximum dimensions allowed by the report.
- Minimum thickness of the partition: 25 mm.

#### **CERTIFICATION**


• CSTB Fire-report no. RS-19-067.

#### **MOUNTING AND FIXING**

Simple installation of the complete access panel using the mounting frame in the wall aperture (about 5-10 mm larger than the installation dimensions). Screws laterally into the wall using flexible swivel fixings.



#### **MOUNTING AND FIXING**



Clearance dimensions: A3 - 15 mm (from 500 x 500) x B3 Aperture dimension: Installation dimension A1 + 5 mm x B1

#### **SIZES AND REFERENCES**

### 2 x 12,5 mm PANELS EI 60 Certificate

DIMENSIONS IN MM A x B (V)	CLEAR OPENING A1 x B1	SIZE FRAME FITTING A2 x B2	SIZE REQUIRED INTERNAL A3 x B3	WIDTH DEPTH T1 T2		REFERENCE
200 x 200	200 x 200	235 x 235	135 x 195	53	20	A09536
300 x 300	300 x 300	335 x 335	235 x 295	53	20	A09537
400 x 400	400 x 400	435 x 435	335 x 395	53	20	A09538
500 x 500	500 x 500	538 x 538	410 x 468	53	25	A09539
600 x 600	600 x 500	638 x 638	510 x 568	53	251	A09540

Dimensions in mm, (V) = closing side. Products not stocked – 3/4 weeks delivery time.

All reports must be validated by your inspection office prior to any order.

